



# INCERT CERTIFICATE

## C-027-1439/a



Issued 13-03-2023  
Expiry date 23-09-2025

Replaces C-027-1439  
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Control panel with LAN communicator  
Trademark: JABLOTRON  
Type designation: JA-107K  
Serial No: 14004035969841  
Hardware / Software: MD12006, MD12705 / MD6111.01.0

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.  
Address: Pod skalkou 4567 /33  
City: 46601 Jablonec nad Nisou  
Country: CZ

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.  
Address: Pod skalkou 4567 /33  
City: 46601 Jablonec nad Nisou  
Country: CZ

Ron Scheepers  
Managing director

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*



## Remarks and observations

The following conditions are applicable:

Category: Control panel

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: A

According to EN 50131-1:2006, this equipment can be applied in installed systems up to and including security grade 2. Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Prosoyo Technology Ltd.

Da Pu Industrial Estate, Gang Zi Distric Chang Ping

Dong Guan

China

Product inspection location:

Distri-Company

Steenweg Deinze 59

Nazareth

Belgium

**Documentation lodged for this INCERT certificate**

Test Reports:

- TESTALARM Praha, Ltd.: 0235\_9355 rev\_1, 24 June 2019
- Cesky metrologicky institut: 8551-PT-E0091-18, 27 April 2018
- Cesky metrologicky institut: 8551-PT-E0146-18, 25 June 2018
- Elektrotechnický Zkušební Ústav: 802795-01\_01, 23 August 2018
- Telefication B.V.: 190400384-001-Ver 2.00, 06 September 2019

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1

February, 2018

**Applied Standards**

**The product as described in this certificate includes the following type designations**

- |                        |                                     |
|------------------------|-------------------------------------|
| - Product description: | Control panel with LAN communicator |
| - Trademark:           | JABLOTRON                           |
| - Type designation:    | JA-107K                             |
| - Hardware version:    | MD12006, MD12705                    |
| - Software version:    | MD6111.01.0                         |
| - Serial number:       | 14004035969841                      |