



INCERT CERTIFICATE

C-027-1443/b



Issued 13-03-2023
Expiry date 11-09-2026

Replaces C-027-1443/a
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Bus PIR motion detector with basic pet immunity
Trademark: JABLOTRON
Type designation: JA-110P PET
Serial No: 14000316671604
Hardware / Software: MU12004 / MU66005

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.



Remarks and observations

The following conditions are applicable:

Category: PIR detector

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

JabloPCB s.r.o.

U Prehrady 5129/67

Jablonec nad Nisou

CZ

Product inspection location:

Distri-Company

Steenweg Deinze 59

Nazareth

Belgium

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication B.V.: 190400393-001-Ver. 1.00, 23 October 2019
- TESTALARM Praha, Ltd.: 2021 9863, 23 February 2021
- VZLU TEST, a.s.: P-VZLUTEST-148/18, 12 June 2018
- Elektrotechnický Zkušební Ústav: 801833-01/01, 28 May 2018
- Cesky metrologicky institut: 8551-PT-E0055-18, 27 March 2018

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1

February, 2018

Applied Standards

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-2-2

November, 2017

EN 50131-1+A1+A2

May, 2017

The product as described in this certificate includes the following type designations

- | | |
|------------------------|---|
| - Product description: | Bus PIR motion detector with basic pet immunity |
| - Trademark: | JABLOTRON |
| - Type designation: | JA-110P PET |
| - Hardware version: | MU12004 |
| - Software version: | MU66005 |
| - Serial number: | 14000316671604 |