



INCERT CERTIFICATE

C-027-1571/a



Issued 13-03-2023
Expiry date 22-02-2028

Replaces C-027-1571
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Bus power output module PG
Trademark: JABLOTRON
Type designation: JB-110N
Serial No: 02337000019396
Hardware / Software: LY10102 / LY63101

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Category: Interface

Security grade: 2

Environmental class: II

Equipment class: Fixed

JB-110N can be installed in set together with Bus module interface for wire detector JA-111H TRB inside of mounting box JA-194PL or JA-195PL.

Factory location:

JabloPCB s.r.o.

U Prehrady 5129/67

Jablonec nad Nisou

CZ

Product inspection location:

Distri-Company

Steenweg Deinze 59

Nazareth

Belgium

Documentation lodged for this INCERT certificate

Test Reports:

- TESTALARM Praha, Ltd.: 2021 9960, 25 June 2021
- Elektrotechnický Zkušební Ústav: 802795-01/01, 23 August 2018
- VZLU TEST, a.s.: P-VZLUTEST-087/16, 23 March 2016
- Cesky metrologicky institut: 8551-PT-E0167-18, 23 July 2018
- TESTALARM Praha, Ltd.: 2021 9930, 09 June 2021
- Telefication B.V.: 200800509-001-Ver2.00, 04 February 2022
- Telefication B.V.: 200701838-001-Ver1.00, 20 January 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1

February, 2018

Applied Standards

EN 50131-3

March, 2009

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2+A3

June, 2020

The product as described in this certificate includes the following type designations

- Product description: Bus power output module PG
- Trademark: JABLOTRON
- Type designation: JB-110N
- Hardware version: LY10102
- Software version: LY63101
- Serial number: 02337000019396