

CERTIFICATE

of constancy of performance

1922 - CPR - 0690

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Control and indicating equipment.

Power supply equipment - teknim Conventional fire alarm panel:

teknim TFP-408 and teknim TFP-404

(with the performance listed, see Annex I and Annex II to 1922-CPR-0690 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of

Bilgi Elektronik San. ve Tic. A.Ş.

**Dudullu Organize Sanayi Bölgesi 1. Cadde İsmet Tarman İş Merkezi No:1, Kat:2
No.32 Ümraniye, İstanbul, Turkey**

and produced in the manufacturing plant of

Bilgi Elektronik San. ve Tic. A.Ş.

**Dudullu Organize Sanayi Bölgesi 1. Cadde İsmet Tarman İş Merkezi No:1, Kat:2
No.32 Ümraniye, İstanbul, Turkey**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006 and EN 54-4:1997,

EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 11.07.2016 and will remain valid until 28.11.2023 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.




Manager: *Anna Vasileva*

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0690/23.11.2020 (page 1 of 1)

Performance list, acc. to EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006

| Essential Characteristics | Performance | Clause |
|---|-------------|--------|
| Performance under fire conditions | | |
| - General requirements | Pass | 4 |
| - General requirements for indications | Pass | 5 |
| - The fire alarm condition | Pass | 7 |
| Response delay (response time to fire) | | |
| - Reception and processing of fire signals | Pass | 7.1 |
| - Output of the fire alarm condition | Pass | 7.7 |
| - Delay to outputs | N/A | 7.11 |
| - Dependencies on more than one alarm signal | N/A | 7.12 |
| Operational reliability | | |
| - General requirements | Pass | 4 |
| - General requirements for indications | Pass | 5 |
| - The quiescent condition | Pass | 6 |
| - The fire alarm condition | Pass | 7 |
| - Fault warning condition | Pass | 8 |
| - Disabled condition | Pass | 9 |
| - Test condition | Pass | 10 |
| - Standardized input/output interface | N/A | 11 |
| - Design requirements | Pass | 12 |
| - Additional design requirements for software controlled control and indicating equipment | Pass | 13 |
| - Marking | Pass | 14 |
| Durability of operational reliability, temperature resistance | | |
| - Cold (operational) | Pass | 15.4 |
| Durability of operational reliability, vibration resistance | | |
| - Impact (operational) | Pass | 15.6 |
| - Vibration, sinusoidal (operational) | Pass | 15.7 |
| - Vibration, sinusoidal (endurance) | Pass | 15.15 |
| Durability of operational reliability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | Pass | 15.8 |
| - Supply voltage variations | Pass | 15.13 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, steady state (operational) | Pass | 15.5 |
| - Damp heat, steady state (endurance) | Pass | 15.14 |



Manager: *Anna Vasileva*

Issued:
Burgas, 23 November 2020

dipl. eng. Anna Vasileva

ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0690/23.11.2020 (page 1 of 1)

Performance list, acc. to EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

| Essential Characteristics | Performance | Clause |
|--|-------------|--------|
| Performance of power supply | | |
| - General requirements | Pass | 4 |
| - Functions | Pass | 5 |
| - Materials, design and manufacture | Pass | 6 |
| Operational reliability | | |
| - General requirements | Pass | 4 |
| - Functions | Pass | 5 |
| - Materials, design and manufacture | Pass | 6 |
| - Documentation | Pass | 7 |
| - Marking | Pass | 8 |
| Durability of operational reliability, temperature resistance | | |
| - Cold (operational) | Pass | 9.5 |
| Durability of operational reliability, vibration resistance | | |
| - Impact (operational) | Pass | 9.7 |
| - Vibration, sinusoidal (operational) | Pass | 9.8 |
| - Vibration, sinusoidal (endurance) | Pass | 9.15 |
| Durability of operational reliability, electrical stability | | |
| - Electromagnetic compatibility (EMC), immunity tests (operational) | Pass | 9.9 |
| Durability of operational reliability, humidity resistance | | |
| - Damp heat, steady state (operational) | Pass | 9.6 |
| - Damp heat, steady state (endurance) | Pass | 9.14 |

This certificate was first issued on 11.07.2016 and will remain valid until 28.11.2023 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Attestation & Certification

Manager:

Anna Vasileva

Issued:
Burgas, 23 November 2020

dipl. eng. Anna Vasileva