



# INCERT CERTIFICATE C-027-1566



Issued 01-11-2021 Replaces  
Expiry date 30-06-2023 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Bus dual PIR and MW motion detector  
Trademark: JABLOTRON  
Type designation: JA-122PW  
Serial No: 14000328206022  
Hardware / Software: ON11008 / ON62101  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.  
Address: Pod Skalkou 4567 /33  
City: 4660 1 JABLONEC NAD NISOU  
Country: Czech Republic

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.  
Address: Pod Skalkou 4567 /33  
City: 4660 1 JABLONEC NAD NISOU  
Country: Czech Republic

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

Telefication B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



# CERTIFICATE

**Remarks and observations**

The following conditions are applicable:

Category: PIR + MW detector

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.  
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

JabloPCB s.r.o.

U Prehrady 5129/67

Jablonec nad Nisou

CZ

Product inspection location:

Distri-Company

Steenweg Deinze 59

Nazareth

Belgium

**Documentation lodged for this INCERT certificate**

Test Reports:

- Telefication B.V.: 200701833-001-Ver. 2.00, 21 September 2021
- TESTALARM Praha, Ltd.: 1215 9643, 13 January 2020
- VZLU TEST, a.s.: P-VZLUTEST-316/19a, 19 November 2019
- Cesky metrologicky institut: 8551-PT-E0251-18, 22 October 2018
- Elektrotechnický Zkušební Ústav: 913080-01/02, 09 January 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1

February, 2018

**Applied Standards**

EN 50130-5

June, 2011

EN 50131-2-4

January, 2008

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2

May, 2017

**The product as described in this certificate includes the following type designations**

- Product description: Bus dual PIR and MW motion detector  
- Trademark: JABLOTRON  
- Type designation: JA-122PW  
- Hardware version: ON11008  
- Software version: ON62101  
- Serial number: 14000328206022

- Product description: Bus dual PIR and MW motion detector  
- Trademark: JABLOTRON  
- Type designation: JA-122PW (G)  
- Hardware version: ON11008  
- Software version: ON62101  
- Serial number: 14000328205120