



INCERT CERTIFICATE

C-027-1438/b



Issued 11-08-2023
Expiry date 11-08-2029

Replaces C-027-1438/a
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Control panel with LAN communicator
Trademark: JABLOTRON
Type designation: JA-103K
Hardware / Software: MD15101.xx / MD6112.xx.x

Placed on the market under the name or trademark of:

Name of the manufacturer: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

This certificate is granted to:

Name of the certificate holder: Jablotron Alarms a.s.
Address: Pod skalkou 4567 /33
City: 46601 Jablonec nad Nisou
Country: CZ

Ron Scheepers
Managing director

This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Category: Control panel
Security grade: 2
Environmental class: II
Equipment class: Fixed
Power supply type: A
ATS category: SP5

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

The x visible in the hw and sw version stands for a digit that can change in case of minor changes.
The certified version is recorded in the certification file together with any reported minor changes.

Factory location:
Prosoyo Technology Ltd.
Da Pu Industrial Estate, Gang Zi Distric Chang Ping
Dong Guan
China

Product inspection location:
Distri-Company
Steenweg Deinze 59
Nazareth
Belgium

Documentation lodged for this INCERT certificate

Test Reports:

- Abegu, A.s.: P_22_01_54, 14 September 2022
- Testalarm Praha, Ltd.: 2022_0221_Corr.1, 30 December 2022
- VZLU TEST, a.s.: P-VZLUTEST-261_22, 30 November 2022
- Telefication B.V.: 190400384-001-Ver 2.00, 26 July 2019

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031+A1+A2	August, 2022
-------------	--------------

Applied Standards

EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50130-4+A1	October, 2014
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020
EN 50131-10	June, 2014

The product as described in this certificate includes the following type designations

- | | |
|------------------------|-------------------------------------|
| - Product description: | Control panel with LAN communicator |
| - Trademark: | JABLOTRON |
| - Type designation: | JA-103K |
| - Hardware version: | MD15101.xx |
| - Software version: | MD6112.xx.x |