

## **CERTIFICATE**



## B-903-0002

We certify that the following components of electrotechnical protection:

Control panel Jablotron JA-106K

Variants: /

Manufacturer: Jablotron Alarms

Distributor:

PG Security Systems

Wilcon Security

produced at: 46601 Jablone nad Nisou - Czech Republic

46601 Jablone nad Nisou - Czech Republic Kaartenmakerstraat 7 - 2984 AN Ridderkerk

Winninglaan 11 - 9140 Temse

with the following specific configuration or application criteria:

maximum system consumption 667mA (excluding battery recharge current) and maximum battery capacity 16Ah

comply with the following specifications:

Brand **INCERT** general regulations (doc. BEC N° 004);

Regulations of **INCERT** product certification (doc. BEC N° 005);

Particular regulations of product certification from **ANPI** (doc. APA TCC9 – 004.01);

Technical Note **BEC** T 014 (3<sup>rd</sup> edition 2013).

on the base of the test report BIS/REC/1219 - 2014.08.29 of the laboratories ANPI.

This certificate is only valid if the components are provided with the mark **INCERT**.

The company

Jablotron Alarms a.s. Pod Skalkou 4567/33 46601 Jablone nad Nisou Czech Republic

is authorised to use the mark **INCERT** on the above mentioned components.

The certificate is granted subject to the INCERT brand
Committee and ANPI terms and conditions and is valid until

17 September 2020

signed on behalf of ANPI Brussels, 18 September 2014

The General Secretary

M. Vandendoren

asbl **ANPI** vzw - Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve **Tel:** +32.10.47.52.11 **Fax:** +32.10.47.52.70 **Email:** info@anpi.be **Internet**: www.anpi.be

This certificate may only be copied completely and without any adding.

CERT PROC 017 CERTIFICATION DRAW UP F ATTEST 005 CERTIFICATE INCERT B PRODUCT E F N V4